

**Sub-Divisional
Water Testing, Laboratory
DWS Sub-Division Teliamura
Khowai, Tripura.**

***WATER TESTING REPORT:-**

Sl. No.	Source of Sample	Date of Collection	Date of Test	Result (mg/l)					Remarks	
				Turbidity (NTU)	PH	Temperature	TDS (mg/l)	Hardness (mg/l)		Iron (mg/l)
1	Teliamura Eng. Medium H/S School, Teliamura, Khowai Tripura.	20-08-25	22-08-25	0.2	6.9	30.1°C	60	74	0.22	<u>P. Limit</u> PH:-6.5-8.5 Turbidity:-05, Iron:-1.0 mg/l. Calcium- 75-200 mg/l. Hardness-200-600 mg/l.



Sr. Research Assistant.
DWS Sub-Division Teliamura
Khowai Tripura.



Assistant Engineer
DWS Sub-Division Teliamura
Khowai Tripura.